



US Army Corps
of Engineers®
Wilmington District

Exhibit 13: Approved Underground Electric Line for Grandfathered Boat Lifts W. KERR SCOTT DAM & RESERVOIR

Private
Residence

2' above
1080' msl

1080' msl
maximum
flood pool

Property Line

Master disconnect switch outside residence on private property with mounted red light installed 2 feet above 1080' msl.

* All systems must have Ground-Fault Circuit-Interrupter (GFCI) protection at circuit breaker box on private property. NO exceptions. Power must be manually disconnected at post and power shut off at master disconnect on private property when not in use.

Breaker/Junction Box with red light. Exit wire in flexible conduit terminating in locking plug. (NEMA (L5 20R, 120 Volt). Cord permanently mounted to breaker/junction box, extra cord length coiled and hung when not in use.

Gangwalk

Lake

DRAWING NOT TO
SCALE